



**Cambridge tap water:
Current information about PFAS testing (May 2022)
Test Results**

	**
PFAS Analyte	Result
PFAS6 (regulated)	ng/L (ppt)
Perfluorooctane Sulfonic Acid (PFOS)	2.9
Perfluorooctanoic Acid (PFOA)	7.6
Perfluorohexane Sulfonic Acid (PFHxS)	2.8
Perfluorononanoic Acid (PFNA)	Not Detected
Perfluorohepatanoic Acid (PFHpA)	2.8
Perfluorodecanoic acid (PFDA)	Not Detected
Sum of PFAS6 - compare to MassDEP MCL of 20 ng/L	16.1

*Trace amounts are present, but below the minimum concentration that can be reported as a quantified value.

MCL = Maximum Contaminant Level

ng/L = nanogram per liter

ppt = parts per trillion

PFAS = Per and Poly Fluoroalkyl Substances

** Average of Split sampling sent to 2 separate certified Laboratories.